

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7210-1320:102 Page 1 of 1

CATEGORY: Flame Detectors

LISTEE: General Monitors, 26776 Simpatica Cr., Lake Forest, CA 92630
Contact: Tony Pipitone (949) 581-4464 Fax (949) 581-8253*

DESIGN: Models FL3000 and FL3001 sensors. Suitable for indoor and outdoor use in temperatures from -40° to 60°C. Suitable for use in Class I, Division 1, Groups B, C and D hazardous locations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, voltage rating and FM label.

APPROVAL: Listed as a flame sensor for use with separately listed compatible control units. Authority having jurisdiction should be consulted prior to installation.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 5, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager